

Application Note

Testing Sampled Values publishers with DANEO 400

Authors

Manfred Rudigier | manfred.rudigier@omicronenergy.com

Fred Steinhauser | fred.steinhauser@omicronenergy.com

Matthias Wehinger | matthias.wehinger@omicronenergy.com

Date

September, 2017

Related OMICRON Product

DANEO 400

Application Area

IEC 61850

Keywords

DANEO 400, Sampled Values, IEC 61850, Implementation Guideline 9-2LE, IEC 61869-9

Version

v2.0

Document ID

ANS_15006_ENU

General information

OMICRON electronics GmbH including all international branch offices is henceforth referred to as OMICRON.

The product information, specifications, and technical data embodied in this Application Note represent the technical status at the time of writing and are subject to change without prior notice.

We have done our best to ensure that the information given in this Application Note is useful, accurate and entirely reliable. However, OMICRON does not assume responsibility for any inaccuracies which may be present.

OMICRON translates this Application Note from the source language English into a number of other languages. Any translation of this document is done for local requirements, and in the event of a dispute between the English and a non-English version, the English version of this note shall govern.

All rights including translation reserved. Reproduction of any kind, for example, photocopying, microfilming, optical character recognition and/or storage in electronic data processing systems, requires the explicit consent of OMICRON. Reprinting, wholly or partly, is not permitted.

© OMICRON 2017. All rights reserved. This Application Note is a publication of OMICRON.

Content

1	Safety instructions	4
2	Introduction.....	5
3	Test environment.....	6
3.1	Configuring the OTMC 100.....	7
3.2	Configuring the CMC test set	8
3.3	Configuring the DANEO 400	9
3.3.1	TAP mode.....	9
3.3.2	Time synchronization	9
3.3.3	Measurement configuration	11
3.3.3.1	Configuration with SCL file	12
3.3.3.2	Verification of configuration	12
4	Testing	13
4.1	General	13
4.1.1	Protocol support.....	13
4.1.2	Accuracy	13
4.2	Observation	14
4.2.1	Observation in DANEO 400 web interface.....	15
4.2.2	Observation in the DANEO Control software	14
4.2.3	Verification of the delay time (Svp1)	16
4.2.4	Verification of the packet interval (Svp8, Svp9)	16
4.2.5	Packet format on link layer (Svp3, Svp6).....	17
4.2.6	Stream information (Svp4, Svp5, Svp14, Svp16).....	17
4.2.7	Sample sequence and timing (Svp8, Svp9, Svp10).....	18
4.3	Measurement.....	19
4.3.1	Comparing measurements (Svp11, Svp12, Svp13).....	19
4.3.2	Use of primary and secondary values.....	20
4.4	Recording	21
4.4.1	Recording in the DANEO Control software	21
4.4.2	PCAP export	22
4.4.3	Analysis in Wireshark (Svp3, Svp4, Svp5, Svp8, Svp9, Svp10, Svp14, Svp15, Svp16).....	24
	List of Literature.....	25

1 Safety instructions

This Application Note may only be used in conjunction with the relevant product manuals which contain all safety instructions. The user is fully responsible for any application that makes use of OMICRON products.

Instructions are always characterized by a ► symbol, even if they are included in a safety instruction.



DANGER

Death or severe injury caused by high voltage or current if the respective protective measures are not complied with.

- ▶ Carefully read and understand the content of this Application Note as well as the manuals of the systems involved before taking them into operation.
- ▶ Please contact OMICRON support if you have any questions or doubts regarding the safety or operating instructions.
- ▶ Follow each instruction listed in the manuals, especially the safety instructions, since this is the only way to avoid the danger that can occur when working on high voltage or high current systems.
- ▶ Only use the equipment involved according to its intended purpose to guarantee safe operation.
- ▶ Existing national safety standards for accident prevention and environmental protection may supplement the equipment's manual.

Only experienced and competent professionals that are trained for working in high voltage or high current environments may implement this Application Note. Additionally, the following qualifications are required:

- Authorized to work in environments of energy generation, transmission or distribution and familiar with the approved operating practices in such environments.
- Familiar with the five safety rules.
- Good knowledge of *DANEO 400*.

2 Introduction

This Application Note shows how the *DANE0 400* is used to verify the correct operation of a Sampled Values publisher.

“Sampled Values” mean digitized current and voltage values from electrical power systems, coded and transmitted over Ethernet networks according to the IEC 61850 (IEC 61850-9-2 Ed 2.0, 2011), in particular to the “9-2LE” implementation guideline of the UCA IUG (UCA International Users Group, Implementation Guideline for Digital Interface to Instrument Transformers Using IEC 61850-9-2), and IEC 61869-9.

References to corresponding test cases (*Svpnn*) from the test procedures for Sampled Values publishers from the UCA IUG testing subcommittee (UCA International Users Group, Testing Subcommittee: Test procedures for Sampled Values Publishers according to the "Implementation Guideline for Digital Interface to Instrument Transformers using IEC 61850-9-2". Version 1.0., 2010) are noted where applicable.

3 Test environment

The test environment as described in UCA International Users Group, Testing Subcommittee: Test procedures for Sampled Values Publishers according to the "Implementation Guideline for Digital Interface to Instrument Transformers using IEC 61850-9-2". Version 1.0., 2010 is shown in Figure 1.

It consists of:

- > The device under test (DUT), which publishes the SV (in this case "9-2LE") stream.
- > A voltage and/or current signal source.
- > A SV ("9-2LE") analyzer.
- > A time synchronization setup.




Figure 1: Generic test environment according to UCA International Users Group, Testing Subcommittee: Test procedures for Sampled Values Publishers according to the "Implementation Guideline for Digital Interface to Instrument Transformers using IEC 61850-9-2". Version 1.0., 2010

For this application note, the generic test environment from Figure 1 is translated into an even simpler test setup as shown in Figure 2, which consists of the following components:

- > A CMC test set (in this case a *CMC 256plus*) with Ethernet interfaces (NET-1B or newer), which functions as a combined SV publisher and voltage/current signal source.
- > A *DANE0 400*, which acts as a SV analyzer.
- > An *OTMC 100*, which acts as a PTP grandmaster clock for the time synchronization of the CMC test set and the *DANE0 400*.

The DUT (typically a merging unit) is omitted, because the SVs are directly generated from the CMC test set.

The *DANE0 400* forwards the PTP traffic over the TAP ports to the CMC. This has the benefit that no PTP transparent switch is required.

The SV stream is transmitted over a direct connection from the CMC to the *DANE0 400*. This ensures that the timing statistics of the measurements are not influenced by any network switch.

All screenshots in this Application Note refer to this test environment, where the devices have been configured as outlined in the following chapters.




Figure 2: Test environment for this application note.

3.1 Configuring the OTMC 100

The *OTMC 100* provides the accurate time for the measurements in this application note (Figure 2). Since both the *DANE0 400* and the CMC test set support PTP (according to the power profile IEEE PC37.238), no PPS is required for this test setup. In case the DUT would require a PPS for time synchronization, the *TICRO 100* (an IEEE 1588/PTP time converter) could be used for such task.

The *OTMC 100* is powered from the *DANE0 400* with Power-over-Ethernet (PoE) and is configured to use the power profile (IEEE PC37.238). For further information on how to configure the power profile in the *OTMC 100*, see the user manual (*OTMC 100 User Manual*. OMICRON electronics GmbH, 2013).

3.2 Configuring the CMC test set

The CMC acts as the DUT and the voltage/current signal generator in this application note. Therefore, the CMC is set up to generate static sine signals at a nominal frequency of 50 Hz for 3 voltage and 3 current signals. The values are listed below:

- > V1: 100 V \angle 0 °
- > V2: 100 V \angle -120 °
- > V3: 100 V \angle 120 °
- > I1: 2 A \angle 0 °
- > I2: 2 A \angle -120 °
- > I3: 2 A \angle 120 °

Note:

The 100 V magnitude is an “even” value, which can be easily set, observed, and verified.

In real secondary systems, values such as $100V/\sqrt{3}$ are typically found. See also 4.3.2.

Those sine signals are generated on the analog outputs and mapped, additionally, into one SV 9-2LE stream with a sampling rate of 4000 Hz (80 samples per cycle) with the following properties:

- > Destination MAC address: 01:0C:CD:04:00:01
- > Source MAC address: 00:50:C2:9B:BE:ED
- > Application ID: 16384 (0x4000)
- > SV ID: OMICRON_CMC_SV1
- > Number of ASDU: 1
- > VLAN ID: 0
- > VLAN priority: 4
- > Simulation/Test: False

The neutral values in the SV stream are calculated and are all zero (except some rounding noise) for balanced systems. For the correct timing of the SV stream, the CMC is time synchronized over PTP by means of the *OTMC 100* (Figure 2).

Further information on how to configure the *CMC 256plus* can be found in the CMC reference manual (CMC User Manual. OMICRON electronics GmbH, 2014).

3.3 Configuring the DANE0 400

DANE0 400 is used to verify the SV stream and the analog output signals from the CMC. This verification can either be done in the *DANE0 Control* software or in the *DANE0 400* web interface. In this chapter the configuration screens are only shown for the *DANE0 Control* software but they are similar in the web interface.

3.3.1 TAP mode

In the test setup of Figure 2, the *DANE0 400* passes on the PTP time to the CMC. Therefore, you should configure port A and B as a network TAP with 100 Mbit/s link speed (Figure 3). This feature of the *DANE0 400* makes it possible that no PTP transparent switch is required, because all traffic between port A and B can pass unimpeded.

Since there is only data link-layer traffic on port A and B, no IP address is required on those ports.




Figure 3: Activated TAP mode.

3.3.2 Time synchronization

PTP time synchronization has to be enabled on the *DANE0 400* for measuring the time characteristics of a 9-2LE publisher. Therefore, the PTP sniffer (Figure 4) is used to select the PTP source for time synchronization. After selecting the time source *DANE0 400* shows the status of the time synchronization (Figure 5). When the clock status icon is green the synchronization is established.




Figure 4: PTP sniffer: The OTMC 100 is found on port A.




Figure 5: PTP status: Synchronization is established.

3.3.3 Measurement configuration

Measured values must be mapped in the *DANE0 Control* software for measuring magnitude and phase of signals in the SV stream from the CMC. Therefore, go to the **System Under Test** view and on the toolbar, click **Find orphans** (Figure 6). Once the SV stream appears in **Orphans**, the dialog can be closed.




Figure 6: The SV stream from the CMC is detected as orphan.

Afterwards, the SV stream appears in the **Navigation** pane, in the **Orphans** list. Select the SV stream and click **Add to IED** in the toolbar or the context menu.

Click the port column in the **DataSet** section of the SV stream, then click **Map** in the toolbar. A new current system and a new voltage system are added to the signal pool (Figure 7).




Figure 7: Mapped SV stream from the CMC received on port B in the signal pool.

Configuration with SCL file

The configuration method shown above uses an arbitrary SV stream (in this case the one published from the CMC), which is sniffed from the network and creates an “ad hoc” configuration based on the sniffed data. Protocol data units are checked for “well formedness” according to the specification, but all other parameters are accepted as found.


In a real installation, the system is engineered and corresponding SCL files, which contain the configuration of the IEDs, are created. Such a file is either an ICD file for a single IED (in this case a merging unit) or a SCD file for the whole substation that contains the data for all configured IEDs. These SCL files can be used to configure the OMICRON tools. Primarily, such a file can be used in the **Sampled Values Configuration** module of the OMICRON **Test Universe** software to set up the CMC to publish Sampled Values exactly with the parameters specified in the SCL file. Secondly, the same file can be loaded into the System under Test in the *DANE0 Control* software. The preparation and mapping can be done even offline, only based on the information from the SCL file.

Verification of configuration

When the System Verification is then started, the detected SV streams on the network are first compared against the loaded definitions from the SCL file.

- > If everything is correctly set up and all parameters match, a green "OK" icon is displayed.
- > If some parameters do not match, a warning icon is displayed and the differences are shown in detail for debugging the problem (Figure 8).

By using this method, based on the information from the SCL files, the correct configuration of the SV stream is verified.



Defined		Found	
SV IEDxMUnn/LLN0\$SV\$MSVCBxx		SV IEDxMUnn/LLN0\$SV\$MSVCBxx	
Details Control block reference: IEDxMUnn/LLN0\$SV\$MSVCBxx Destination MAC address: 01-0C-CD-04-00-01 Application ID: 16384 (0x4000) SV ID: OMICRON_CMC_SV1 Sample rate: 4000 Sample mode: Samples per second noASDU: 1 DataSet reference: IEDxMUnn/LLN0\$PhsMeas VLAN ID: 0 VLAN priority: 4 Configuration revision: 1 Source MAC address: False Simulation/Test: False Synchronization status: Globally synchronized (2) Number of DataSet entries: 16		Details Control block reference: IEDxMUnn/LLN0\$SV\$MSVCBxx Destination MAC address: 01-0C-CD-04-00-01 Application ID: 16385 (0x4001) SV ID: OMICRON_CMC_SV1 Sample rate: 4000 Sample mode: Samples per second noASDU: 1 DataSet reference: IEDxMUnn/LLN0\$PhsMeas VLAN ID: 0 VLAN priority: 5 Configuration revision: 1 Source MAC address: 20-B7-C0-00-3E-4D Simulation/Test: False Synchronization status: Globally synchronized (2) Number of DataSet entries: 16	

Figure 8: Example of a verification difference (application ID and VLAN priority mismatch).

4 Testing

4.1 General

With the following three *DANE0 400* features most tests defined in (UCA International Users Group, Testing Subcommittee: Test procedures for Sampled Values Publishers according to the "Implementation Guideline for Digital Interface to Instrument Transformers using IEC 61850-9-2". Version 1.0., 2010) can be covered with minimal effort:

- > Observation
- > Measurement
- > Recording

The use of these features is extensively described in this chapter. Each use description contains a reference to the corresponding test IDs in (UCA International Users Group, Testing Subcommittee: Test procedures for Sampled Values Publishers according to the "Implementation Guideline for Digital Interface to Instrument Transformers using IEC 61850-9-2". Version 1.0., 2010).

4.1.1 Protocol support

The *DANE0 400* is able to capture and analyze SV streams with the following properties:

- > Ethertype: 0x88BA
- > Number of ASDUs: between 1 and 8
- > Sampling rate: between 600 and 15360 Hz
- > Dataset: PhsMeas1 specified by 9-2LE (8 channels with 8 quality fields). However, more channels are allowed, but cannot be mapped as signals in the signal pool at the moment.

DANE0 400 is able to subscribe to streams with an arbitrary combination of those properties and not just the ones defined by the implementation guideline (UCA International Users Group, Implementation Guideline for Digital Interface to Instrument Transformers Using IEC 61850-9-2). Consequently, the *DANE0 400* can handle SV variants according to the upcoming standard IEC 61869-9 (IEC 61869-9 Ed. 1.0, 2014).

4.1.2 Accuracy


The *DANE0 400* is able to time stamp every received Ethernet packet in hardware with a time stamping resolution of 10 ns. The time stamping on all three Ethernet ports within one *DANE0 400* refers to a common clock, so calculating relative timings from time stamps recorded within one *DANE0 400* works perfectly without synchronizing to an external clock. For absolute time measurements, the *DANE0 400* can be synchronized over PTP with a precision better than 500 ns.

4.2 Observation

The live observation is possible in the *DANE0 Control* software and in the *DANE0 400* web interface. By using the live observation, most of the SV stream characteristics can be verified immediately.

4.2.1 Observation in the *DANE0 Control* software

Go to the **System Under Test** view and select the previously configured SV stream in the **Navigation** pane. Then, expand the **Statistics** table to show the SV observation details (Figure 9).



The screenshot shows the OMICRON DANE0 Control software interface. The main window is titled "Acquisition1.dac - OMICRON DANE0 Control". The "System Under Test" tab is active, and the "Observation" sub-tab is selected. The left navigation pane shows a tree structure under "IEDx" with "LD MUnn" and "SV OMICRON_CMC_SV1" selected. The main area displays the details for the selected SV stream, "IEDxMUnn/LLN0\$SV\$MSVCBxx".

Details

Control block reference	IEDxMUnn/LLN0\$SV\$MSVCBxx
Destination MAC address	01-0C-CD-04-00-01
Application ID	16384 (0x4000)
SV ID	OMICRON_CMC_SV1
Sample rate	4000
Sample mode	Samples per second
noASDU	1
DataSet reference	IEDxMUnn/LLN0\$PhsMeas
VLAN ID	0
VLAN priority	4
Configuration revision	1
Source MAC address	20-B7-C0-00-3E-4D
Simulation/Test	False
Synchronization status	Globally synchronized (2)
Number of DataSet entries	16

Statistics


	A	B	ETH
Receive time		2017-08-18 14:48:20.436	
Samples seen		526001	
Samples missed		0	
Sampling rate		4,000 kHz	
Last packet smpCnt=0		2017-08-18 14:48:20.000	
Clock drift (current)		-70,02 µs	
Clock drift (since start)		-50,69 µs	
Timed out		False	
Timed out count		0	
Packet interval:			
Minimum		106,60 µs	
Maximum		392,96 µs	
Average		250,00 µs	
Packet delay:			
Minimum		34,42 µs	
Maximum		219,70 µs	
Average		95,78 µs	

Figure 9: The stream from the CMC is observed on port B (*DANE0 Control* software).

4.2.2 Observation in DANE0 400 web interface

Go to **Observation > Sampled Values** page and click **Start**. A list of sniffed SV streams from all network ports appears in **Sniffed Sampled Values**. By selecting a sniffed SV stream, the observed stream details appear in **Observed SV details** (Figure 10).

Note that during observation new streams do not appear in **Sniffed Sampled Values** (the sniffing is paused).



The screenshot shows the DANE0 400 web interface. The left sidebar contains navigation options: Home, Network, Observation (GOOSE, Sampled Values), Publishing, Acquisition, Recordings, Time (PTP Sniffer), and System. The main area is titled 'DANE0 1 - DJ171G' and has 'Start' and 'Stop' buttons. Below the buttons is a 'Sniffed Sampled Values (Paused)' section with a search bar and a table:

SV ID	Port	Simulated
OMICRON_CMC_SV1	B	No

Below the table is a large play button icon. To the right is the 'Observed SV details' panel:

Destination MAC address	01:0C:CD:04:00:01
Source MAC address	20:B7:C0:00:3E:4D
Application ID	16384 (0x4000)
SV ID	OMICRON_CMC_SV1
Number of ASDU	1
VLAN ID	0
VLAN priority	4
Configuration revision	1
Simulation/Test	False
Synchronization status	Synchronized (2)

Below this are sections for 'Quality', 'Statistics', 'Packet interval', and 'Packet delay'.

Received time	2017-08-18 14:43:56.887388
Samples seen	569999
Samples missed	0
Sampling rate	4000 Hz
Last zero packet time	2017-08-18 14:43:56.000094
Clock drift (current)	-40376 ns
Clock drift (since start)	-9352 ns
Timed out	False
Timeout count	0

Packet interval	
Minimum	106680 ns
Maximum	389928 ns
Average	250000 ns

Packet delay	
Minimum	34920 ns
Maximum	222288 ns
Average	95500 ns

Figure 10: The stream from the CMC is observed on port B (DANE0 400 web interface).

4.2.3 Verification of the delay time (Svp1)

The delay time is the period between the theoretical time instant of sampling the analog value from the primary process until the Ethernet packet (contains the corresponding sampled value) is published from the DUT.

DANE0 400 measures the packet delay for every received SV frame to calculate the packet delay statistics (minimum, maximum, average). This can be used to verify that the delay time is within the limit of 3 ms. Note that this only works if the SV publisher is synchronized to the same time source as the *DANE0 400*.

Packet delay

Minimum	34512 ns
Maximum	227056 ns
Average	98435 ns

Figure 11: Packet delay statistics of the CMC.

In Figure 11, the measurement was running for about one minute. It shows the maximum measured delay of the CMC, which was $\sim 230 \mu\text{s}$, frankly within the allowed tolerance of 3 ms. Since the *DANE0 400* is taking every received frame into account (not just the frame with `smpCnt = 0`), meaningful statistics are already available after a few seconds. This is possible because *DANE0 400* calculates the expected packet arrival time for each packet based on sampling rate and sample counter.

4.2.4 Verification of the packet interval (Svp8, Svp9)

The packet interval is the time between two Ethernet packets of a SV stream.

The *DANE0 400* uses the time of the arrival of two SV packets to calculate the packet interval statistics (minimum, maximum, average). This information can be used to diagnose if the SV publisher is sending the packets with the correct frequency. The correct packet frequency depends on the number of ASDU and the sampling rate (sampling rate / noASDU).

Packet interval

Minimum	104920 ns
Maximum	390240 ns
Average	250000 ns

Figure 12: Packet interval statistics of the CMC.

In Figure 12, the average interval between two consecutive packets after measuring for about one minute was 250 μs . This value arose due to the fact the CMC was using one ASDU and a sampling rate of 4000 Hz. Note that the *DANE0 400* is taking every received SV packet into account, so meaningful statistics are already available after a few seconds.

4.2.5 Packet format on link layer (Svp3, Svp6)

The sampled values frame parser of the *DANE0 400* is parsing according to the 9-2LE implementation guideline (UCA International Users Group, Implementation Guideline for Digital Interface to Instrument Transformers Using IEC 61850-9-2). Any parsing error due to an invalid packet layout is shown in the live statistics with a special error flag.

Possible errors that can be detected:

- > Unexpected fields are encountered (e.g. refresh time and sample rate should not be there).
- > Missing fields are detected (e.g. application ID is missing, reserved 1 or 2 is missing...).
- > Data set has less than 4 currents / 4 voltages with the corresponding quality fields.
- > Encoding errors (e.g. invalid tags or lengths).
- > Invalid values (e.g. number of ASDU is less than 1 or greater than 8).

4.2.6 Stream information (Svp4, Svp5, Svp14, Svp16)

If the parsing of frames is successful, all properties appear as parsed from the SV stream.

Observed SV details	
Destination MAC address	01:0C:CD:04:00:01
Source MAC address	20:B7:C0:00:3E:4D
Application ID	16384 (0x4000)
SV ID	OMICRON_CMC_SV1
Number of ASDU	1
VLAN ID	0
VLAN priority	4
Configuration revision	1
Simulation/Test	False
Synchronization status	Synchronized (2)

Figure 13: Observed SV application layer properties.

This can be used to verify that the observed application layer values are identical to the published ones. In this example, the observed values using *DANE0 400* are identical to the ones published by the CMC (see chapter 3.2).

Note that the simulation flag and the synchronization status are updated whenever they change on the wire. The verification of the correct values of the 9-2LE publisher can be done easily this way:

- > Synchronization status: e.g. by disconnecting the PTP master or by forcing a value with the CMC.
- > Simulation/test flag: e.g. by changing it on the CMC.

Furthermore, the *DANE0 400* also accepts SV streams without a VLAN tag. In this case, VLAN ID and VLAN priority fields are not shown.

4.2.7 Sample sequence and timing (Svp8, Svp9, Svp10)

The *DANE0 400* evaluates the `smpCnt` field of every received packet for its statistics (Figure 14). This helps you verifying that the SV publisher is correctly incrementing and resetting the `smpCnt`.

Statistics	
Received time	2017-08-18 15:00:54.191584
Samples seen	1702000
Samples missed	0
Sampling rate	4000 Hz
Last zero packet time	2017-08-18 15:00:54.000094
Clock drift (current)	-35488 ns
Clock drift (since start)	-34176 ns
Timed out	False
Timeout count	0

Figure 14: Sample sequence and timing statistics.

You can find out the following problems by easily checking the statistics:

- > The detected sampling rate does not match the configured sampling rate at the publisher:
The *DANE0 400* detects the sampling rate by observing the reset to zero (e.g., last seen 3999, new seen 0, hence the sampling rate is 4000). If this number is not correct, packets are either missing or the publisher does not reset the count.
- > “Samples missed” is not 0:
The *DANE0 400* counts the minimum number of missing ASDUs. The *DANE0 400* will recognize if the `smpCnt` is not incremented correctly at each received ASDU. This could either happen if SV packets are dropped somewhere in the network or the SV publisher does not behave correctly.
- > The fraction of seconds’ part of “Last zero packet time” is not close to 0:
The *DANE0 400* is showing the time stamp of the last received SV packet with `smpCnt = 0`. According to 4.2.3, the value has to be lesser than 3 ms. This allows to verify that the SV publisher sends this frame at the beginning of each new second. Note that this value is only meaningful if the SV publisher and the *DANE0 400* are synchronized to the same time source.
- > “Samples seen” is not incremented, “Timed out” is true, “Timeout count” is not zero:
The *DANE0 400* continuously observes the presence of the SV stream and counts the received packets. If the SV publisher stops sending SV packets, the counter does not increment any more. Also the “Timed out” field would then be true. Since the UI is only refreshed every second, short timeouts would not be visible. Therefore, an additional value “Timeout count” is calculated, which indicates how often the SV stream has been interrupted for more than 3 ms (which is equal to the maximum permitted time delay of an SV packet).
- > “Clock drift (current)” and “Clock drift (since start)” are not close to 0:
The *DANE0 400* evaluates if its clock and the one of the SV publisher are synchronous or drifting away from each other. This evaluation is done by calculating the time duration between the last two received samples with `smpCnt = 0`, which should be exactly one second. Any deviation from the expected interval of one second is shown as “Clock drift (current)”. This field indicates how much the clock of the DUT deviated in the past second, whereas the “Clock drift (since start)” is the accumulated clock drift since starting the observation. In case the “Clock drift (since start)” field does not remain close to 0 (and is therefore constantly increasing), the SV publisher is either not synchronized to the same time source as the *DANE0 400* or the SV publisher has a timing issue.

4.3 Measurement

The *DANE0 400* is a hybrid measurement system, capable of measuring analog input signals from physical inputs and digital inputs (SV streams) simultaneously. With this feature it is possible to verify if the SV stream generated by the DUT matches with the physical analog values and if the voltage/current scaling parameters are applied correctly.

4.3.1 Comparing measurements (Svp11, Svp12, Svp13)

Go to the **Observation** view in the *DANE0 Control* software. For each phase system, drag the **Phasors** and **Instantaneous Values** from the **Signal pool** to observation sheets.

The live values of the physical voltages / currents generated by the CMC (see chapter 3.2 for the configured phasor values) appear in **V analog** and **I analog** system. The measured values from the SV stream are shown in **V OMICRON_CMC_SV1** and **I OMICRON_CMC_SV1** system. In this example, they contain the same values as the physical signals, so the 9-2LE stream contains the correctly scaled values.




Figure 15: Measured phasors of physical and virtual analog signals generated by the CMC.




Figure 16: Measured instantaneous Values of physical and virtual analog signals generated by the CMC.

4.3.2 Use of primary and secondary values

By definition, values conveyed by Sampled Values are primary values. For example, when merging units with non-conventional sensors, there are no secondary values accessible at all. Then, of course, ratios and scaling factors need to be considered.

The ratios for the signal generation in the CMC are located in the device settings of the test object in the OMICRON *Test Universe* software. These ratios also determine the scaling of the Sampled Values. The test modules also support the direct use of primary values in the user interface. By using this feature, the settings in the test modules correspond to the generated Sampled Values.

The concept of *DANE0 400* is also to use primary values. This is also for the general case, where secondary values do not exist, which can be increasingly expected with Sampled Values applications. The corresponding scaling factors need to be calculated according to the instructions in the user manual (*DANE0 400 User Manual*. OMICRON electronics GmbH, 2014) and set in the **Inputs** configuration of the *DANE0 Control* software.

4.4 Recording

4.4.1 Recording in the *DANE0 Control* software

The SV traffic can be recorded in PCAP format for an Ethernet packet-level analysis. Therefore, go to **Recording** and click **Traffic**. From **Network ports**, select the appropriate Ethernet port (here the traffic from the CMC is received on port B), and on the toolbar, click **Record**.




Figure 17: Recording the SV traffic of the CMC on port B.

Since there are thousands of packets published per second, a large number of packets is captured in a short time. Clicking **Stop** quickly after starting the recording captures enough packets for most evaluations. The software offers you to open the finished recording in the analysis. If you accept, the **Analysis** window appears (Figure 18).

4.4.2 PCAP export

The analysis, when opened directly after the recording has finished, is automatically added to **Selected recordings**, where its details appear (Figure 18). This recording lasted for about 5 seconds with a total size of 3 MB. It contains the complete captured SV traffic of the CMC from port B.




Figure 18: The **Analysis** shows SV recording details.

Now click **Collect** to download the data from the *DANE0 400*, then click **Export**. A new dialog appears to select the data to export (Figure 19).





Figure 19: Export dialog where the PCAP export is selected for port B, which should be directly opened in Wireshark.

4.4.3 Analysis in Wireshark (Svp3, Svp4, Svp5, Svp8, Svp9, Svp10, Svp14, Svp15, Svp16)

Figure 20 shows the time synchronized PCAP recording of *DANE0 400* in Wireshark. In this example, a packet with `smpCnt = 0` has been selected where the time was 15:22:39.000041904. This result shows that the CMC test set is time synchronized to the same PTP clock as *DANE0 400*, because the frame with `smpCnt = 0` was seen ~ 42 μ s after the top of the second.



No.	Time	Source	Protocol
1833	15:22:38,997883320	OmicronE_00:3e:4d	IEC61850 Sa
1834	15:22:38,998041920	OmicronE_00:3e:4d	IEC61850 Sa
1835	15:22:38,998337088	OmicronE_00:3e:4d	IEC61850 Sa
1836	15:22:38,998561688	OmicronE_00:3e:4d	IEC61850 Sa
1837	15:22:38,998887568	OmicronE_00:3e:4d	IEC61850 Sa
1838	15:22:38,999042336	OmicronE_00:3e:4d	IEC61850 Sa
1839	15:22:38,999378336	OmicronE_00:3e:4d	IEC61850 Sa
1840	15:22:38,999568144	OmicronE_00:3e:4d	IEC61850 Sa
1841	15:22:38,999889744	OmicronE_00:3e:4d	IEC61850 Sa
1842	15:22:39,000041904	OmicronE_00:3e:4d	IEC61850 Sa
1843	15:22:39,000379552	OmicronE_00:3e:4d	IEC61850 Sa
1844	15:22:39,000537152	OmicronE_00:3e:4d	IEC61850 Sa
1845	15:22:39,000860992	OmicronE_00:3e:4d	IEC61850 Sa
1846	15:22:39,001037320	OmicronE_00:3e:4d	IEC61850 Sa
1847	15:22:39,001343080	OmicronE_00:3e:4d	IEC61850 Sa
1848	15:22:39,001564488	OmicronE_00:3e:4d	IEC61850 Sa
1849	15:22:39,001875368	OmicronE_00:3e:4d	IEC61850 Sa
1850	15:22:39,002049328	OmicronE_00:3e:4d	IEC61850 Sa
1851	15:22:39,002386976	OmicronE_00:3e:4d	IEC61850 Sa
1852	15:22:39,002545616	OmicronE_00:3e:4d	IEC61850 Sa
1853	15:22:39,002844224	OmicronE_00:3e:4d	IEC61850 Sa
1854	15:22:39,003037624	OmicronE_00:3e:4d	IEC61850 Sa
1855	15:22:39,003337352	OmicronE_00:3e:4d	IEC61850 Sa
1856	15:22:39,003535872	OmicronE_00:3e:4d	IEC61850 Sa
1857	15:22:39,003835952	OmicronE_00:3e:4d	IEC61850 Sa
1858	15:22:39,004036240	OmicronE_00:3e:4d	IEC61850 Sa
1859	15:22:39,004335600	OmicronE_00:3e:4d	IEC61850 Sa
1860	15:22:39,004535800	OmicronE_00:3e:4d	IEC61850 Sa
1861	15:22:39,004835928	OmicronE_00:3e:4d	IEC61850 Sa
1862	15:22:39,005035848	OmicronE_00:3e:4d	IEC61850 Sa
1863	15:22:39,005335448	OmicronE_00:3e:4d	IEC61850 Sa

```

> Frame 1842: 131 bytes on wire (1048 bits), 131 bytes captured (1048 bits) on interface 0
> Ethernet II, Src: OmicronE_00:3e:4d (20:b7:c0:00:3e:4d), Dst: Ie
> 802.1Q Virtual LAN, PRI: 4, DEI: 0, ID: 0
  IEC61850 Sampled Values
    APPID: 0x4000
    Length: 113
    Reserved 1: 0x0000 (0)
    Reserved 2: 0x0000 (0)
  savPdu
    noASDU: 1
  seqASDU: 1 item
    ASDU
      svID: OMICRON_CMC_SV1
      smpCnt: 0
      confRef: 1
      smpSynch: global (2)
      seqData: ffd4dcb400000000016abb900000000014778c0000
  
```

0000 01 0c cd 04 00 01 20 b7 c0 00 3e 4d 81 00 80 00
0010 88 ba 40 00 00 71 00 00 00 60 67 80 01 01 a2 ..@..q..
0020 62 30 60 80 0f 4f 4d 49 43 52 4f 4e 5f 43 4d 43 b0 ..OMI
0030 5f 53 56 31 82 02 00 00 83 04 00 00 00 01 85 01 _SV1..
0040 02 87 40 ff d4 dc b4 00 00 00 00 00 16 ab b9 00 ..@.....
0050 00 00 00 00 14 77 8c 00 00 00 00 ff ff ff f9 00w..
0060 00 20 00 ff 12 bd 84 00 00 00 00 00 7c b0 d4 00
0070 00 00 00 00 70 91 c3 00 00 00 00 00 00 00 1b 00p...
0080 00 20 00 ..

Figure 20: Sampled Values stream from the CMC captured with the *DANE0 400* in Wireshark.

List of Literature

CMC User Manual. OMICRON electronics GmbH. (2014).

DANEO 400 User Manual. OMICRON electronics GmbH. (2014).

IEC 61850-9-2 Ed 2.0. (2011). Communication networks and systems for power utility automation - Part 9-2: Specific Communications Service Mapping (SCSM) – Sampled values over ISO/IEC 8802-3.

IEC 61869-9 Ed. 1.0. (2014). Instrument Transformers - Part 9: Digital Interface for Instrument Transformers. Committee draft.

OTMC 100 User Manual. OMICRON electronics GmbH. (2013).

UCA International Users Group. (2010). Testing Subcommittee: Test procedures for Sampled Values Publishers according to the "Implementation Guideline for Digital Interface to Instrument Transformers using IEC 61850-9-2". Version 1.0.

UCA International Users Group. (s.d.). Implementation Guideline for Digital Interface to Instrument Transformers Using IEC 61850-9-2.

Support

When you are working with our products we want to provide you with the greatest possible benefits. If you need any support, we are here to assist you.



24/7 Technical Support – Get Support

www.omicronenergy.com/en/support

At our technical support hotline, you can reach competent, well-educated technicians for all of your questions. Around the clock and free of charge.

Make use of our 24/7 international technical support hotline:

Europe / Middle East / Africa	+43 59495 4444
Americas	+1 713 830-4660 +1 800-OMICRON
Asia-Pacific	+852 3767 5500

Additionally, on our website you can find our Service Center or Sales Partner closest to you.



Customer Portal – Stay Informed

www.omicronenergy.com/en/support/customer

The Customer Portal on our website is an international knowledge exchange platform. Download the latest software updates for all our products and share your own experiences in our user forum.

Browse through the knowledge library and find application notes, conference papers, articles about daily working experiences, user manuals and much more.



OMICRON Academy – Learn More

www.omicronenergy.com/en/support/training

Learn more about your product in one of the training courses offered by the OMICRON Academy.

For more information, additional literature, and detailed contact information of our offices worldwide please visit our website.